

valspar

FLUROPON[®]

CERTIFIED LABORATORY TEST REPORT

ACCELERATED WEATHERING QUV-A

TEST PROCEDURES:	ACCELERATED WEATHERING 3000 HOURS QUV-A, 340 NM BULB ASTM D 4587, ASTM G 154
PRODUCT TESTED:	VALSPAR FLUROPON [®]
TEST RESULTS:	ACCEPTABLE
FILM INTEGRITY:	NO CRACKING, PEELING, BLISTERING LOSS OF ADHESION OF THE COATING
CHALKING:	CHALK RATING OF 8 OR BETTER ASTM D 4214, METHOD A
COLOR CHANGE:	NO MORE THAN 2 ΔE HUNTER UNITS PER ASTM D 2244
LOCATION:	THE VALSPAR CORPORATION FT. MYERS, FLORIDA, USA

 4/15/14

Marlene Garrow - Ft. Myers
Valspar Corporation

Date

The VALSPAR CORPORATION certifies these test to be true and accurate and performed by our laboratory.

04/14