

valspar

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

CORROSION - SALT SPRAY

TEST PROCEDURES:

SALT SPRAY – 1000 HOURS PER
ASTM B 117

PRODUCT TESTED:

VALSPAR FLUROPON®

SUBSTRATE:

HDG OR GALVALUME

TEST RESULTS:

ACCEPTABLE CORROSION
RATED PER ASTM D 1654

- FIELD* 10
- SCRIBE 1/16 INCH (2mm)
- RUST (ASTM D 610) 10

*FIELD REFERENCE ASTM D 714
NO BLISTERING

LOCATION:

THE VALSPAR CORPORATION
FT. MYERS, FLORIDA, USA

 4/15/14

Marlene Garrow - Ft. Myers
Valspar Corporation

Date

The VALSPAR CORPORATION certifies these test to be true and accurate and performed by our laboratory.

04/14