



AkzoNobel

Tomorrow's Answers Today

CERTIFIED LABORATORY TEST REPORT

SPECULAR GLOSS

Test Procedure: Finished roof surfaces shall have a specular gloss value of 15 ± 5 at an angle of 60 degrees when measured in accordance with ASTM D 523.

Test Results: Coated sheet has a specular gloss value between 10 and 20 gloss when measured as above.

Product Tested: TRINAR®

Date Tested: January 24, 2012

Location: Akzo Nobel Coatings Inc., Columbus, Ohio

Certified by:

Lori Witherup
Manager
Building Products Technology