

valspar

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

ABRASION - FALLING SAND

TEST PROCEDURES:

FALLING SAND PER
ASTM D 968 METHOD A

PRODUCT TESTED:

VALSPAR FLUROPON®

SUBSTRATE:


HDG, GALVALUME OR ALUMINUM

TEST RESULTS:

ACCEPTABLE
80 LITERS / MIL \pm 5 LITERS

LOCATION:

THE VALSPAR CORPORATION
FT. MYERS, FLORIDA, USA



04/15/14

Marlene Garrow - Ft. Myers
Valspar Corporation

Date

The VALSPAR CORPORATION certifies these test to be true and accurate and performed by our laboratory.

04/14