



**SHERWIN-WILLIAMS.**  
Coil Coatings

# FLUROPON®

## CERTIFIED LABORATORY TEST REPORT

### ABRASION - FALLING SAND

TEST PROCEDURES:

FALLING SAND PER  
ASTM D 968 METHOD A

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

HDG, GALVALUME OR ALUMINUM

TEST RESULTS:

ACCEPTABLE  
80 LITERS / MIL ± 5 LITERS

LOCATION:

THE SHERWIN-WILLIAMS COMPANY  
FT. MYERS, FLORIDA, USA

  
Marlene Garrow  
Group Leader


05/30/2019

Date

  
Alexander J. Nicol  
Notary Public

5/30/19

Date



Notary Public stamp with expiration date

The SHERWIN-WILLIAMS COMPANY certifies these tests to be true, accurate and performed by our laboratory.

03/19