

## **FLUROPON**®

## CERTIFIED LABORATORY TEST REPORT

## **ADHESION BY TAPE**

**TEST PROCEDURES:** 

**ADHESION OF COATING BY TAPE-OFF** 

**ASTM D 3359, METHOD B** 

**PRODUCT TESTED:** 

**FLUROPON®** 

**SUBSTRATE:** 

HDG, GALVALUME OR ALUMINUM

**TEST RESULTS:** 

ACCEPTABLE – NO COATING WAS REMOVED BY 610 SCOTCH TAPE ON

THE TEST AREA

LOCATION:

THE SHERWIN-WILLIAMS COMPANY

FT. MYERS, FLORIDA, USA

Karlen Garrow

05/30/2019

Marlene Garrow Group Leader Date

Alexander J. Nicol Notary Public Date

ALEXANDER J. NICOL State of Florida-Notary Public Commission # GG 240196 My Commission Expires July 19, 2022

Notary Public stamp with expiration date