



SHERWIN-WILLIAMS.
Coil Coatings

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

CYCLIC SALT FOG UV

TEST PROCEDURES:

CYCLIC SALT FOG UV – 6 CYCLES PER
ASTM D 5894 (2016 HOURS)

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

HDG, GALVALUME OR ALUMINUM

TEST RESULTS:

ACCEPTABLE CORROSION


- FIELD 8
- SCRIBE 1/32 INCH (1mm)
- RUST (ASTM D 610) 10

LOCATION:

THE SHERWIN-WILLIAMS COMPANY
FT. MYERS, FLORIDA, USA

Marlene Garrow 05/30/2019
Marlene Garrow Date
Group Leader

Alexander J. Nicol 5/30/19
Alexander J. Nicol Date
Notary Public



Notary Public stamp with expiration date

The SHERWIN-WILLIAMS COMPANY certifies these tests to be true, accurate and performed by our laboratory.