

Marlene Garrow

Group Leader

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

EXTERIOR DURABILITY

TEST:	FLORIDA EXTERIOR DURABILITY, PER ASTM G 7
TEST PROCEDURE:	HDG, GALVALUME OR ALUMINUM PANEL PROPERLY COATED AND WEATHERED IN FLORIDA AT 45° FACING SOUTH FOR 20 YEARS
PRODUCT TESTED:	FLUROPON [®]
COLOR:	NO MORE THAN FIVE (5) ΔE HUNTER UNITS COLOR CHANGE PER ASTM D 2244
CHALK:	RATING NO LESS THAN EIGHT (8) PER ASTM D 4214 METHOD A
LOCATION:	THE SHERWIN-WILLIAMS COMPANY FT. MYERS, FLORIDA, USA
V 4.64	Manha A Ninul 5/20/10



Notary Public stamp with expiration date

Alexander J. Nicol

Notary Public

Date