



SHERWIN-WILLIAMS
Coil Coatings

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

FLEXIBILITY – T-BEND

TEST PROCEDURES:

T-BEND PER
ASTM D 4145

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

HDG, GALVALUME AND ALUMINUM

TEST RESULTS:

T-BEND = 2T

LOCATION:

THE SHERWIN-WILLIAMS COMPANY
FT. MYERS, FLORIDA, USA


Marlene Garrow
Group Leader


05/30/2019

Date


Alexander J. Nicol
Notary Public

5/30/19

Date



Notary Public stamp with expiration date

The SHERWIN-WILLIAMS COMPANY certifies these tests to be true, accurate and performed by our laboratory.

03/19