

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

FORMABILITY

TEST PROCEDURES:

1/8 INCH (3 MM) MANDREL TEST

180º BEND PER ASTM D 522

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

HDG, GALVALUME OR ALUMINUM

TEST RESULTS:

ACCEPTABLE

(NO LOSS OF ADHESION)

LOCATION:

THE SHERWIN-WILLIAMS COMPANY

FT. MYERS, FLORIDA, USA

Karlene Larrow

05/30/2019

Marlene Garrow Group Leader Date

Alexander J. Nicol Notary Public

Date

A Str

The SHERWIN-WILLIAMS COMPANY certifies these tests to be true, accurate and performed by our laboratory.

ALEXANDER J. NICOL State of Florida-Notary Public Commission # GG 240196 My Commission Expires July 19, 2022

tamam with assistant as alst