



SHERWIN-WILLIAMS.
Coil Coatings

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

HUMIDITY

TEST PROCEDURES:

3000 HOURS, 100% HUMIDITY
ASTM D 2247

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

ALUMINUM

TEST RESULTS:

ACCEPTABLE CORROSION

- FIELD 10
- CUT EDGE 10 (0 MM)
- UNCUT EDGE 10 (0 MM)


ACCEPTABLE BLISTERING PER ASTM D 714

LOCATION:

THE SHERWIN-WILLIAMS COMPANY
FT. MYERS, FLORIDA, USA

Marlene Garrow 05/30/2019
 Marlene Garrow Date
 Group Leader

Alexander J. Nicol 5/30/19
 Alexander J. Nicol Date
 Notary Public



Notary Public stamp with expiration date

The SHERWIN-WILLIAMS COMPANY certifies these tests to be true, accurate and performed by our laboratory.