

FLUROPON®

CERTIFIED LABORATORY TEST REPORT

IMPACT RESISTANCE

TEST PROCEDURES:

REVERSE IMPACT USING 1.5X METAL

THICKNESS IN INCH LBS. (KILOGRAM-METERS) ½ INCH

(13MM) BALL INDENTER

(GARDNER IMPACT TESTER) PER

ASTM D 2794

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

ALUMINUM

TEST RESULTS:

ACCEPTABLE

NO CRACKING

NO LOSS OF ADHESION

LOCATION:

THE SHERWIN-WILLIAMS COMPANY

FT. MYERS, FLORIDA, USA

05/30/2019

Marlene Garrow Group Leader

Date

Alexander J. Nicol Notary Public

ALEXANDER J. NICOL State of Florida-Notary Public Commission # GG 240196 My Commission Expires July 19, 2022

Notary Public stamp with expiration date