

valspar

FLUROPON®

**CERTIFIED LABORATORY
TEST REPORT**

PENCIL HARDNESS

TEST PROCEDURES:

FILM HARDNESS BY PENCIL PER
ASTM D 3363

PRODUCT TESTED:

VALSPAR FLUROPON®

TEST RESULTS:

PENCIL HARDNESS = HB MINIMUM
USING EAGLE TURQUOISE PENCILS

LOCATION:

THE VALSPAR CORPORATION
FT. MYERS, FLORIDA, USA

 4/15/14

Marlene Garrow - Ft. Myers
Valspar Corporation

Date

The VALSPAR CORPORATION certifies these test to be true and accurate and performed by our laboratory.

04/14