



**SHERWIN-WILLIAMS**  
Coil Coatings

# FLUROPON®

## CERTIFIED LABORATORY TEST REPORT

### WATER RESISTANCE OF COATINGS USING WATER FOG APPARATUS

TEST PROCEDURES:

WATER FOG 2000 HOURS  
ASTM D 1735

PRODUCT TESTED:

FLUROPON®

SUBSTRATE:

HDG, GALVALUME OR ALUMINUM

TEST RESULTS:


ACCEPTABLE – NO BLISTERING  
NO LOSS OF ADHESION

LOCATION:

THE SHERWIN-WILLIAMS COMPANY  
FT. MYERS, FLORIDA, USA

Marlene Garrow 05/30/2019  
Marlene Garrow Date  
Group Leader

Alexander J. Nicol 5/30/19  
Alexander J. Nicol Date  
Notary Public



Notary Public stamp with expiration date

The SHERWIN-WILLIAMS COMPANY certifies these tests to be true, accurate and performed by our laboratory.